

Request for Quotes

Power Distribution Unit Equipment and Installation

30-2015/2016



ADDENDUM #1

Deadline for Quotes have been extended to April 22, 2016, 2:00 pm, local time

Below are questions received and their corresponding responses. Duplicated questions have been omitted.

Question: When do you anticipate award?

Response: Our goal is to award as soon as possible and time availability scheduled around college activities.

Question: When are questions due?

Response: Questions need to be sent to purchasing@pensacolastate.edu by 4:00 pm on Friday, April 15, 2016 Central time.

Question: Can Installation be done on nights and weekends?

Response: Yes, the goal is to minimize as much downtime with the transition as possible.

Question: Will someone be available during the entire time of installation?

Response: Yes.

Question: Does the equipment have to be free standing?

Response: Yes.

Question: Can the flooring be reinforced?

Response: Yes.

Question: Does the equipment have to be same as existing equipment?

Response: The proposer may offer any brand for which he is an authorized representative, which meets or exceeds the specification for any items and approved by college.

Question: What is the Equipment currently running off?

Response: The current equipment is powered by Liebert UPS. Therefore, any proposing equipment will need to be compatible.

Question: Can equipment be stored on site prior to install?

Response: Yes, as long as equipment doesn't block pathway and impede on accessibility to any existing equipment.