

DISTRICT BOARD OF TRUSTEES
PENSACOLA JUNIOR COLLEGE
1000 COLLEGE BOULEVARD
PENSACOLA, FL 32504-8998

March 27, 2008

ADDENDUM NO. 2

TO

INVITATION TO BID (ITB 5-2007/2008) for FABRICATION & INSTALLATION OF METAL STAIRS FOR BUILDINGS# 97, 98, & 99 ON THE PENSACOLA CAMPUS OF PENSACOLA JUNIOR COLLEGE

This is your written notification that the following changes have been made to the original bid specifications:

1. At the upper stair run, a guardrail is not required at the side adjacent to the existing building wall. Handrails attached to the building are acceptable.
2. All guardrails must be constructed such that no sphere 4" in diameter or greater can pass through any opening. There is a discrepancy of the method by which to achieve this – the written specifications call for vertical pickets between top and bottom rails – the drawings show 'horizontal' runs of 1-1/2" metal tube. Vertical pickets are acceptable.

Please include this signed form with your bid submittal. Do not fax.

If you have any questions, please call me at 850.484.1794.

Angie C. Jones
Director of Purchasing
and Auxiliary Services

Please acknowledge and return this addendum with your bid. If you have already submitted a bid, please return this addendum, with signed acknowledgment, by the bid opening deadline, **2:00 p.m., April 8, 2008.**

ADDENDUM ACKNOWLEDGED BY: _____

FIRM/ENTITY _____

SIGNATURE OF REPRESENTATIVE: _____