

DISTRICT BOARD OF TRUSTEES  
PENSACOLA STATE COLLEGE  
1000 COLLEGE BOULEVARD  
PENSACOLA, FL 32504-8998

August 27, 2010

ADDENDUM NO. 1  
TO  
REQUEST FOR PROPOSAL RFP 4 – 2010.11 BUILDING 15 LIGHTING RETROFIT

The following are all the answers to the questions we received for the referenced RFP based on the specifications and mandatory pre-proposal on August 19, 2010:

Q. Will the vendor be responsible for replacing any ceiling tile damaged during the project?

A. **Yes, we would like the vendor to replace the ceiling tiles upon completion of the project. The tile is: Armstrong 538B Travertone Acoustical Ceiling Material, Citrus High CAC, beveled Tegular, Humiguard Plus, 24x24 white. Please make this a part of your pricing.**

Please add the following to Section I – General Conditions:

**27. UTILIZATION OF SUBCONTRACTORS: At the time of bid opening, the bidder shall submit a complete list of all subcontractors he intends to utilize to perform the work under the contract. Licensure of subcontractors is specified in item 28 below.**

**28. LICENSURE: In accordance with Chapter 489.113, Florida Statutes, all individuals or entities engaging in and providing construction services shall be licensed in the State of Florida for that activity. This license requirement includes general and sub-contractors.**

**The successful low bidder shall be required to submit a list of all contractors to be involved in said project with applicable license numbers (see form included in these documents), including a photographic copy of current license certificates. Submittal of proof of license shall be made with and as a part of signed contract.**

The bulb wattage in Room 1590 is 250 watts.

The project needs to be completed NLT mid December due to gallery showings the first of January.

Drawings have already been sent and no written questions were received.

All other requirements remain the same.

*Angie C. Jones*

Director of Purchasing  
and Auxiliary Services

Please acknowledge and return this addendum with your proposal. If you have already submitted a proposal, please return this addendum, with signed acknowledgment, by the proposal opening deadline, **September 8, 2010** at 11:00 a.m. CST. Addendum cannot be faxed or emailed.

ADDENDUM ACKNOWLEDGED BY: \_\_\_\_\_

FIRM/ENTITY \_\_\_\_\_

SIGNATURE OF REPRESENTATIVE: \_\_\_\_\_